

CERTIFICATE OF COMPLIANCE

Certificate Number 20160428-EX26998
Report Reference EX26998-20160428
Issue Date 2016-APRIL-28

Issued to: TIGER STEEL INDUSTRIES
P.O BOX 31165
ABUDHABI UNITED ARAB EMIRATES

This is to certify that
representative samples of


METALLIC SPRINKLER PIPE
Schedule 10, 20, 30, and 40 steel sprinkler pipe for wet,
dry, preaction and deluge type sprinkler systems intended
to be joined by threading, welding, or Listed Rubber
Gasketed Fittings when installed in accordance with the
fitting manufacturer's specifications.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852, Metallic Sprinkler Pipe for Fire Protection Service
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

